

1/E-1.0 ELECTRIC DEMO NOTES

- ① EXISTING UTILITY METER #66347 LOCATED IN SITE 13 SERVES SITES 1-28. 2 MAIN CIRCUIT BREAKER: 125 AMP 240 VOLT 2-POLE BREAKER AND 150 AMP 240 VOLT 2-POLE BREAKER. REPLACED UNDER ALTERNATE 2.
- ② EXISTING UTILITY METER #64941 LOCATED IN SITE 43 SERVES SITES 29-57. 2 MAIN CIRCUIT BREAKER: 125 AMP 240 VOLT 2-POLE BREAKER AND 150 AMP 240 VOLT 2-POLE BREAKER. REPLACED UNDER ALTERNATE 2.
- ③ EXISTING UTILITY METER #66348 LOCATED IN SMALL SHED AT SITE 87A SERVES SITES 76-98. 4 MAIN CIRCUIT BREAKER: 125 AMP 240 VOLT 2-POLE BREAKER, 125 AMP 240 VOLT 2-POLE BREAKER, 125 AMP 240 VOLT 2-POLE BREAKER, AND 40 AMP 240 VOLT 2-POLE BREAKER. REPLACED UNDER BASE BID.
- ④ EXISTING UTILITY METER #66346 LOCATED IN EXISTING SHOWER ROOM (WHICH WILL BE REMOVED DURING RENOVATIONS) SERVES SHOWER ROOM AND SITES 65-74. REPLACED IN NEW LOCATION UNDER BASE BID.
- ⑤ EXISTING TRANSFORMER TO BE REPLACED AND RELOCATED UNDER BASE BID.
- ⑥ EXISTING TRANSFORMER TO BE REPLACED UNDER ALTERNATE BID #1.
- ⑦ EXISTING TRANSFORMER TO BE RELOCATED UNDER BASE BID, REPLACED UNDER ALTERNATE BID #2.

GENERAL NOTES

RV SITE NUMBERING IS MODIFIED BETWEEN DEMOLITION DRAWINGS AND NEW CONSTRUCTION DRAWINGS.

CONTRACTOR TO SITE LOCATE ALL EXISTING SERVICES, INFORMATION SHOWN IS BASED ON SITE OBSERVATIONS AND INFORMATION PROVIDED BY OWNER. INFORMATION IS NOT GUARANTEED AND IS FOR ESTIMATING PURPOSES ONLY.

CONTRACTOR TO RELOCATE EXISTING TRANSFORMERS AS DESCRIBED ON SHEET E1.1. CONTRACTOR RESPONSIBLE FOR FIELD LOCATING EXISTING CONDUIT SERVING TRANSFORMER AND RELOCATING TO NEW TRANSFORMER LOCATION. CONTRACTOR TO COORDINATE ALL WORK WITH COOS CURRY ELECTRIC PRIOR TO PERFORMING ANY WORK.


CONTRACTOR TO REPLACE SERVICES AS DESCRIBED ON SHEET E1.1. ALL NEW SERVICES TO BE STAINLESS STEEL CABINETS DESIGNED FOR COASTAL ENVIRONMENT. CONTRACTOR RESPONSIBLE FOR COORDINATION WITH COOS CURRY ELECTRIC FOR CONNECTION TO NEW TRANSFORMER.

CONTRACTOR TO UPDATE ALL PANEL SCHEDULES AT END OF CONSTRUCTION WITH NEW SITE NUMBERS.

CONTRACTOR TO COORDINATE RELOCATION OF WIFI REPEATER IN EXISTING RESTROOM BUILDING TO NEW RESTROOM BUILDING. PROVIDE RECEPTACLE FOR LOW VOLTAGE TRANSFORMER.



CONTRACTOR TO PROVIDE ADDITIONAL SPLITTERS TO EXTEND CABLE TELEVISION TO NEW SITES. RELOCATE TERMINATION TO NEW PEDESTALS.

1 SITE ELECTRICAL DEMO PLAN
SCALE: 1/64" = 1'-0"



125 WEST CENTRAL AVENUE
SUITE 400
COOS BAY, OREGON 97420
TEL: (541) 269-5388
www.crowclay.com

CROW/CLAY & ASSOCIATES INC.
ARCHITECTURE AND PLANNING
LAND USE AND INTERIORS



PORT OF BROOKINGS HARBOR
RV PARK -
BOAT BASIN ROAD
BROOKINGS, OREGON 97415

REVISIONS	
Revision:	Date:

PROJECT NO: 19005

E1.0